

State Water Resources Control Board

November 6, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7016 3010 0000 5907 1837

Mr. Keith Underwood
Marina Manager
City of Sacramento Fleet Management
2710 Ramp Way
Sacramento, California 95818
kunderwood@cityofsacramento.org

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM
LOCATED AT THE SACRAMENTO MARINA, 2710 RAMP WAY, SACRAMENTO**

Dear Mr. Underwood:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on October 24, 2017, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Monitoring or Testing Records Onsite – The annual monitoring certification records for 2015, 2016, and 2017 were not onsite at the time of inspection. Additionally, there were no secondary containment testing records onsite at the time of inspection.	Unleaded	October 24, 2017	Ongoing	H&SC 25293; 23 CCR 2712(b)
2	Failure to Monitor Product Piping – The sensor located in the under dispenser containment 1/2 was raised and the sensor located in the transition sump on the hillside was not vertical and, therefore, unable to detect a leak at the earliest opportunity.	Unleaded	October 24, 2017	Ongoing	23 CCR 2630(d)

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Sacramento County Environmental Management Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA

Ms. Jennea Monasterio
Environmental Specialist
Sacramento County Environmental
Management Department
10590 Armstrong Avenue, Suite A
Sacramento, California 95655
monasterioj@saccounty.net

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Jennea Monasterio
Environmental Specialist
Sacramento County Environmental
Management Department
monasterioj@saccounty.net